

DOWN HAWK ONLY

APPLICATION FOR SEPTIC SYSTEM PERMIT

FLOYD COUNTY HEALTH DEPARTMENT

PERMIT NO. 96-156

YES	NO		
	✓	PERIMETER DRAIN	DATE <u>6/11/96</u> TYPE SYSTEM <u>COND</u>
✓		DISTRIBUTION BOX (ES)	INSTALLER'S NAME <u>BRYAN STUMLER</u>
✓		2" ROCK ABOVE TILE	INSTALLER'S PHONE NUMBER
✓		4" ROCK AROUND TILE	OWNER'S NAME <u>MARTY HALEY</u>
✓		6" ROCK BELOW TILE	JOB LOCATION <u>5624 Hwy 111</u> <u>FRANKLIN TWP</u>
✓	✓	STRAW COVER (6 INCHES)	LOT NO.
	✓	GEOTEXTILE FABRIC COVER (3 1/2 MP)	LOT SIZE
	✓	THIS IS A NEW HOME	WATER SOURCE <u>WELL</u>
	✓	BUSINESS BUILDING	LIQUID CAPACITY OF SEPTIC TANK <u>1000</u> DOSE TANK
SOIL RATING <u>3</u>		HYDROMATIC PUMP SIZE	
NUMBER OF BEDROOMS <u>FOR SUMMER TRAILER ONLY</u>		DEPTH OF TRENCH <u>26"</u> WIDTH OF TRENCH <u>36"</u>	
SQUARE FOOTAGE OF HOME		LENGTH OF SEPTIC LATERAL <u>500'</u>	
NO. OF TONS OF 5-L RIVER GRAVEL <u>92 TONS</u>		LENGTH OF WASHER LATERAL	

NOTE: In space at side draw a plot diagram showing the size and shape of lot, location of building, septic system, drive way, roads, wells and streams. Measured distances of the above must be shown. On approval of application the system must be installed as indicated.

SITE SURVEY Paul Stager

APPROVED 6/11/96 DISAPPROVED _____

FINAL INSPECTION Paul Bannenhaver

APPROVED 8-20-96 DISAPPROVED _____

REMARKS _____

NOTICE

SYSTEMS ARE TO BE INSTALLED IN DRY WEATHER CONDITIONS WITH APPROVED SOIL CONDITIONS. SEPTIC SYSTEM SITE TO BE PROTECTED. NO TRAFFIC EXCAVATION OR STORAGE OF MATERIALS. VIOLATION COULD RESULT IN PERMIT BEING REVOKED.



