Castle Valley Consultants, Inc.
Engineers • Planners • Design Professionals
1011 Daisy Point Road, Pottstown, Pa. 19465
Phone (610) 469-8414 Fax (610) 469-8415
Web www.casval.com

INSPECTION REPORT

DATE:	5/23/10	**PROJECT:**	U & O Transfer
TIME:		**PERMIT #:**	
ADDRESS:	1314 Main Street	**INSPECTION:**	U & O Transfer
INSPECTOR:	Ed Mullen	**PASS/FAIL:**	Fail

COMMENTS / OBSERVATIONS:

Roof drains must be corrected to not be connected to public sewer or diverted.
No working Smoke Detectors or CO detectors.
No Fire extinguisher in kitchen
No GFCI protected outlets in kitchen, Bathrooms, Exterior & Basement utility sink. All outlets are operational.
Exterior handrail on side patio steps loose.
Cracked concrete on side patio steps & section missing
Handrail on steps outside of kitchen are loose
Patio a rear of property has cracked concrete & section missing
Rubbish is around exterior driveway
Exterior outlet at garage is not GFCI protected
Gas line where meter cap.
No Inspection for Furnace.
No Inspection for the fireplace

Em 5/23/10